



STANDARD TESTING LABORATORY

PLOT NO. 782, KANJHWLA INDUSTRIAL AREA, DELHI-110081

PH. : 9310136322, 9310136320

E-mail : standardtestinglaboratory@yahoo.com, info@standardtestinglab.com



TC-12167

Issued to: - M/s Deen Bandhu Public School
Ghevra, Delhi-110081

F.F No.7.8.01.05
Report No. : 230927002671
Date of Report: 03/10/2023
Analysis End Date: 03/10/2023
Analysis Start Date: 28/09/2023
Date of Receipt: 27/09/2023
ULR No: TC121672300001548F
Party Ref. No.: DBPS/09/2023
dtd: 27.09.2023

Sample Described: Drinking Water

TEST REPORT

S.No. Tests	Requirements IS-10500-2012	Result
1. Colour, Hazen Unit	5 Max for acceptable limit 15 Max for permissible limit	< 5
2. Odour,	Agreeable	Agreeable
3. Turbidity, NTU	1 Max for acceptable limit 5 Max for permissible limit	< 1
4. pH Value	6.5 to 8.5	8.13
5. Total Hardness (as CaCO ₃) mg/l	200 Max for acceptable limit 600 Max for permissible limit	6
6. Iron (as Fe), mg/l	0.1 Max for acceptable limit No relaxation for permissible limit	0.021
7. Chlorides (as Cl), mg/l	250 Max for acceptable limit 1000 Max for permissible limit	7
8. Total Dissolved Solid, mg/l	500 Max for acceptable limit 2000 Max permissible limit	46
9. Fluoride (as F), mg/l	1.0 Max for acceptable limit 1.5 Max for permissible limit	0.031

Remark: The sample conforms to IS: 10500-2012 with respect to above test.

(Page 1 of 1)

End

Principal
Deen Bandhu Public School
Ghevra, Delhi-110081



(1) The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither Inferred nor implied.
(2) Total liability of our Lab is limited to the invoiced amount. (3) Samples will be destroyed after 90 days from the date of test certificate unless specified otherwise. (4) This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of Law and should not be used in any advertising media without our special permission in writing (5) Report refer to the sample submitted to us and not drawn by Standard Testing Laboratory unless mentioned otherwise